Computer simulation of energy use, greenhouse gas emissions, and process economics of the fluid milk process¹

P. M. Tomasula,*² W. C. F. Yee,† A. J. McAloon,† D. W. Nutter,‡ and L. M. Bonnaillie*

*Dairy and Functional Foods Research Unit, and

†Engineering and Scale-up, Process and Economics Research Support Group, United States Department of Agriculture, Agricultural Research Service, Eastern Regional Research Center, 600 E. Mermaid Lane, Wyndmoor, PA 19038

‡University of Arkansas, Mechanical Engineering Department, Fayetteville 72701

ABSTRACT

Energy-savings measures have been implemented in fluid milk plants to lower energy costs and the energy-related carbon dioxide (CO₂) emissions. Although these measures have resulted in reductions in steam, electricity, compressed air, and refrigeration use of up to 30%, a benchmarking framework is necessary to examine the implementation of process-specific measures that would lower energy use, costs, and CO₂ emissions even further. In this study, using information provided by the dairy industry and equipment vendors, a customizable model of the fluid milk process was developed for use in process design software to benchmark the electrical and fuel energy consumption and CO₂ emissions of current processes. It may also be used to test the feasibility of new processing concepts to lower energy and CO₂ emissions with calculation of new capital and operating costs. The accuracy of the model in predicting total energy usage of the entire fluid milk process and the pasteurization step was validated using available literature and industry energy data. Computer simulation of small (40.0 million L/yr), medium (113.6 million L/yr), and large (227.1 million L/yr) processing plants predicted the carbon footprint of milk, defined as grams of CO₂ equivalents (CO_{2e}) per kilogram of packaged milk, to within 5% of the value of 96 g of CO_{2e}/kg of packaged milk obtained in an industry-conducted life cycle assessment and also showed, in agreement with the same study, that plant size had no effect on the carbon footprint of milk but that larger plants were more cost effective in producing milk. Analysis of the pasteurization step showed that increasing the percentage regeneration of the pasteurizer from 90 to 96%

would lower its thermal energy use by almost 60% and that implementation of partial homogenization would lower electrical energy use and CO_{2e} emissions of homogenization by 82 and 5.4%, respectively. It was also demonstrated that implementation of steps to lower non-process-related electrical energy in the plant would be more effective in lowering energy use and CO_{2e} emissions than fuel-related energy reductions. The model also predicts process-related water usage, but this portion of the model was not validated due to a lack of data. The simulator model can serve as a benchmarking framework for current plant operations and a tool to test cost-effective process upgrades or evaluate new technologies that improve the energy efficiency and lower the carbon footprint of milk processing plants.

Key words: greenhouse gas, milk processing, specific energy consumption, economics

INTRODUCTION

High concentrations of greenhouse gases (GHG) in the atmosphere, which absorb and emit the thermal infrared radiation reflected by the earth's surface, clouds, or atmosphere, have been implicated as a cause of global climate change (IPCC, 2007). Although GHG occur naturally, the increases in global average temperatures are very likely due to the increases in GHG concentrations resulting from anthropogenic or human activities (IPCC, 2007). Water vapor, carbon dioxide (CO₂), methane (CH₄), nitrous oxide (N₂O), and ozone are naturally occurring GHG, but CO₂, CH₄, and N₂O are represented in increased amounts due to human activities: 83.4% of the total GHG are CO₂ emissions resulting from fossil fuel burning for electricity production, industry, transportation, and commercial and residential needs; 9.5% are CH₄ emissions from agriculture, landfills, coal, oil, and gas operations; and 4.9% are N₂O emissions from agriculture and fossil fuel use. Other GHG (2.1%) include industrial gases such as the halocarbons, which are typically used as refrigerants, and may contain fluorine, bromine, or chlorine (EPA, 2012). Greenhouse gas emissions for all gases are usually

Received September 29, 2012.

Accepted January 25, 2013.

¹Mention of trade names or commercial products in this publication is solely for the purpose of providing specific information and does not imply recommendation or endorsement by the US Department of Agriculture. The USDA is an equal opportunity provider and employer.

²Corresponding author: peggy.tomasula@ars.usda.gov

reported in terms of CO₂ equivalents (CO_{2e}) because of their differences in properties and lifetimes in the atmosphere. In terms of the global warming potential over a 100-yr time horizon, CH₄ is 25 times more potent than CO₂, N₂O is 298 times more potent than CO₂, and halocarbons are from 124 to 14,800 times more potent than CO₂ (IPCC, 2007).

In the United States, agricultural practices contribute 6.3% of total GHG emissions mainly due to emissions of CH₄ and N₂O, with a much smaller contribution from CO₂ emissions (EPA, 2012). Using life cycle analysis (LCA), Thoma et al. (2012) demonstrated that the entire dairy sector contributes approximately 1.9% of total US GHG emissions. The total carbon footprint of milk, which was defined as the sum of the GHG emissions calculated for each stage of the fluid milk supply chain per unit quantity of milk, was reported as 17.6 pounds of CO_{2e}/gal of fluid milk consumed (2.12 kg of CO_{2e}/kg of fluid milk consumed). A second LCA conducted by the Aurora dairies (Cashman et al., 2009) also reported a carbon footprint of milk of 17.6 pounds of CO_{2e}/gal (2.12 kg of CO_{2e}/kg of milk) for organic milk production. Both LCA showed that the bulk of GHG emissions in fluid milk production occurred on the farm as CH₄ because of enteric fermentation of cows and, to a lesser extent, manure handling and N₂O because of feed production.

However, the bulk of GHG emissions beyond the farmgate are mainly energy-related CO₂ emissions because of fossil fuel use. Natural gas and fossil fuel-generated electricity are used to process and package milk; diesel fuels are used to transport and distribute milk; and electricity is used for cold storage of milk at the plant or distribution point and in the consumer's home. Some emissions are due to leakage of refrigerants. For milk processing and packaging alone, the carbon footprint of milk, obtained by LCA, was reported as 96 g of CO_{2e}/kg of packaged milk (Tan et al., 2011; Thoma et al., 2012). Considering that approximately 26 billion kg of fluid milk is processed in the United States each year (IDFA, 2007) and that 553 million t of milk are produced worldwide (FAO, 2010), emitting a total of about 1,328 million t of CO_{2e}, reduction of energy usage in the processing sector would lower CO_{2e} emissions significantly as well as the costs associated with milk processing.

Efforts to mitigate GHG emissions throughout the processing sector have led to the implementation of best practices in plants, following an energy audit to establish a performance baseline or benchmark that follows the exchange of energy and mass between the plant and the environment over time. Use of best practices have helped processing plants reduce energy use in the form of steam, electricity, compressed air,

and refrigeration by 5 to 30% (Doty and Turner, 2009; Tomasula and Nutter, 2011). To compare benchmarked individual plants to the average industry performance, Xu and Flapper (2009) reported energy information data for fluid milk plants throughout the United States and other dairying countries. The energy performance in the United States, reported in terms of the specific energy consumption (SEC), the energy usage of the entire plant divided by the total fluid milk production, ranged from 0.2 to 6.0 MJ/kg of fluid milk. This large variation in performance indicates significant opportunities for energy savings in this sector (Xu and Flapper, 2009).

To achieve further reductions in energy, a model that simulates the fluid milk process would allow benchmarking of current plant operations and examination of the contributions of the individual process unit operations, or related sections of a plant, to its total energy performance (Tomasula and Nutter, 2011). The model may also be used as a tool to investigate process operating conditions or process modifications to lower GHG emissions and energy use.

Process simulation is a well-established, powerful tool that has been used by the chemical process industries for years to optimize current plant operations or to assist in the design of new plants. A process simulator is a computer program that links modules representing the unit operations to perform mass and energy balances at each unit operation and over the entire process. Each module is a mathematical representation of the physical processes that occurs in the unit operation. Once constructed, the mass and energy flows of each component of the process and, in some programs, the costs associated with the process, may be predicted for each unit operation and over the entire process. However, adaptation of commercial software for chemical processing to food processing scenarios requires significant modification before use (Cheng and Friis, 2007). The goal of this study was to develop a customizable process simulation tool for the fluid milk industry, based on commercial software, to benchmark GHG emissions by calculating the carbon footprint for milk and energy usage and economics for the total process operation and for each unit operation; to validate the model using literature and industry data; and to apply the model in a variety of processing scenarios.

MATERIALS AND METHODS

Model Development

The commercial software package, SuperPro Designer (<http://www.intelligen.com>; version 8.5 build 6; Intelligen Inc., Scotch Plains, NJ), which contains models

Figure 1. Process flow sheet of the fluid milk model. Full homogenization is used. CIP = cleaning-in-place.

for 140 general unit operations for equipment, such as heaters and coolers, heat exchangers, flow mixers and splitters, homogenizers, centrifuges, and tanks, all of which are applicable to the development of a flow sheet and simulation of the fluid milk process, was used in this study. The models for the unit operations are represented by icons. The icons were used to develop the flow sheet diagram of the fluid milk process, as shown in Figure 1, with an overview of the unit operations and

operating conditions used in this study for a base model processing 40.0 million L/yr given in Table 1.

Description of the Model by Section

The base fluid milk process depicted by the flow sheet of Figure 1 is roughly separated into sections for milk reception and storage, milk standardization, milk homogenization, milk pasteurization, milk packaging,

Table 1. Overview of unit operations in Figure 1 for the base fluid milk model processing 40,000,000 L/yr of whole milk¹

Unit ID	Description ²	Detail
A-HX101	Raw milk cooler	3.3°C outlet temperature; glycol cooling medium
A-TK102	Silo tanks	16-h residence time
A-TK103	Balance tank	1-h residence time
B-HX102	First preheat regenerating section	64°C exit temperature of cold milk; 7.0°C exit temperature of pasteurized milk; 99.8 m ² heat transfer area
B-HX103	Second preheat regenerating section	72.3°C exit temperature of cold milk; 68.6°C exit temperature of pasteurized milk; 12.1 m ² heat transfer area
B-HX104	Milk pasteurizer	77.2°C exit temperature of cold milk; 5.0 m ² heat transfer area
B-HTB121	Milk holding tube	22-s residence time
C-DG122 and -HX106	Deaerator	Temperature decrease of 8°C
C-CS124	Centrifugal separator	162.5 L/min throughput; 40% fat content in overflow; 0.05% fat content in underflow; 81.7% of cream remix back with skim milk
C-TK105	Cream holding tank	4-h residence time
D-HG127	Homogenizers	198 bar pressure drop; 63.7°C exit temperature; 52.7-kW power consumption
B-HX115	Chiller	1.7°C outlet temperature; glycol cooling medium
F-TK104	Milk storage tanks	1.5-h residence time
E-HX107	Cream preheat regeneration section	85.0°C exit temperature of cold cream; 63.6°C exit temperature of pasteurized cream; 0.4 m ² heat transfer area
E-HX108	Cream pasteurizer	90.0°C exit temperature of cold cream; 0.07 m ² heat transfer area
E-HTB101	Cream holding tube	15-s residence time
F-BM201	Blow molding—HDPE gallon jugs	2,479 jugs per hour; 58 g of resin per jug; 111-kW operating power
F-FL203	Milk filling/packaging	25-kW operating power
G-FL214	Cream filling/packaging; paper pint packaging	3.7-kW operating power
K-DSR204, -DSR205	Cold storage for milk and cream	4,600-m ² storage area; 555-kW refrigeration power
H-V106	CIP tank for cream pasteurizer	5-kW auxiliary power
H-V107	CIP tank for milk pasteurizer	5-kW auxiliary power
F-V108	CIP tank for tank gardens	5-kW auxiliary power
H-V109	CIP tank for filling machines	5-kW auxiliary power
I-WT101	Aeration tank	6-h average hydraulic residence time; 23-h sludge residence time
I-WT102	Clarifier	1% solids content
I-WT103	Belt filter press	15% solids content
I-WT104	Sludge dryer	35% final solids content

¹The first letter of the unit ID identifies the location of the unit in the figure.²HDPE = high-density polyethylene; CIP = cleaning-in-place.

storage, cleaning-in-place (CIP) operations, and wastewater treatment. All pipelines, tanks, and equipment for processing are assumed to be constructed of sanitary, food-grade stainless steel and to meet 3-A Standards (McLean, VA; <http://www.3-a.org>).

Milk Reception and Storage. After the cows are milked, the raw milk is cooled and maintained at a maximum temperature of 7°C in a bulk tank at the farm (FDA, 2011), although many fluid milk processors recommend that their suppliers cool milk to 4°C. It is sampled and checked for quality at the farm and then transported in sanitary stainless steel tanker trucks to the processing plant in an unrefrigerated but insulated tanker truck. Once at the plant, the milk is sampled for bacteria and antibiotics and milk temperature is recorded. It is then pumped from the tanker by a high-speed pump to stainless steel milk silos for storage. A metering unit is placed in the line to monitor the flow. The milk silos are insulated to maintain milk at 4°C within a standard time frame of about 24 h and are available in sizes up to 265,000 L. They are also equipped with an agitator to prevent cream separation. The raw milk is pumped from the silos to a balance tank to ensure a constant supply to the milk standardization and pasteurization section.

Milk Standardization and Pasteurization. Milk standardization is the precise addition of cream to the skim milk through computer process control to yield milk with the desired fat content. To begin the process, the milk from the balance tank is drawn by the timing pump to the first regeneration section of the pasteurizer (preheat section). After heating, a vacuum-deaeration step may be used to remove dissolved air that may cause off-flavors and aromas in the milk or cream products. Because the simulator does not include a module for deaeration, the pressure in the expansion vessel is adjusted to a value that results in a boiling point temperature about 8°C below the inlet temperature. The vacuum pump removes the dissolved air, causing the temperature of milk to decrease from 64 to 56°C. The cooling block following the deaerators is used to model the temperature decrease. The deaerator is followed by a high-speed centrifugal separator designed for efficient separation of cream from milk. The separator ejects waste solids on an hourly basis, which are directed to the waste management section of the plant. The fat content of the cream was assumed as 40% and that of the skim milk as 0.05%. The cream and skim milk were blended to create 3.25% milk (whole milk) using a split block in the model. Adjusting the split block appropriately also allows simulation of a plant producing skim or 1 or 2% milk.

The excess cream is directed to storage and further processing. The cream may be processed into heavy

cream, light cream, half and half, buttermilk, and other products.

Homogenization. A high-pressure homogenizer is used to reduce the size of the milk fat globules so that they remain suspended in milk during storage. A 2-stage homogenizer is assumed in the model, with an outlet pressure of 20 MPa. For every 4-MPa drop in pressure, milk temperature is increased by 1°C. The largest size of homogenizer on the market accommodates milk flow rates of up to approximately 30,000 L/h. Some larger plants have 2 or more homogenizers online to accommodate the larger production rates. An alternative to homogenizers for accommodation of the entire milk stream is partial homogenization, in which only the cream stream is homogenized (Figure 2).

Pasteurization of Milk and Cream. The HTST pasteurizer in this model is simulated by 5 plate heat exchangers in series. The homogenization step completes the regenerative preheating of milk by the pasteurized milk in the second and third heat exchangers. The homogenized milk then enters the final heating section of the pasteurizer, where it is heated to an assumed temperature of 77°C (171°F) and held for 22 s in a holding tube. The Pasteurized Milk Ordinance (FDA, 2011) mandates a minimum pasteurization temperature for milk of 72°C and holding time of 15 s.

While the raw milk is preheated by pasteurized milk in the second and third heat exchangers, it is heated in the pasteurizing heat exchanger by hot water produced by steam heating of water in the final heating step. The percentage regeneration is calculated as follows:

$$\text{Percentage regeneration} = \frac{\text{temperature (T) increase caused by regeneration}}{\text{total temperature change in milk}} = \frac{(T_{\text{after regeneration}} - T_{\text{feed}})}{(T_{\text{pasteurization}} - T_{\text{feed}})}.$$

Following holding, the pasteurized milk flows to the opposite side of the plate heat exchanger, where it is cooled by regenerative cooling. The pasteurized milk then enters the chilling section, where it is cooled to 4°C by cold water chilled using the coolant glycol.

Excess cream is also pasteurized using HTST pasteurization but at a temperature of 90°C, with a holding time of 15 s in this study. The percentage regeneration was assumed as 94% in the regenerator sections of the pasteurizers unless otherwise noted.

Skid-mounted pasteurizer units come in various sizes to accommodate processing capacity and can process up to approximately 34,000 L of milk/h. Processors may have one or more units to handle various products or demand.

Filling/Packaging. In the 40.0 million L/yr base model that was developed for the fluid milk process,

assumed to be purchased. Milk or cream is filled using filling machines. A dairy may have several filling machines.

Cold Storage. After packaging, the milk and cream may be stored on site, delivered to a distribution center, or delivered directly to a retailer. Some plants also store nondairy products such as juices. The simulation model assumes a storage area of up to 4,600 m² for storing packaged milk at 1.8°C for up to 1.5 d, but

allows the user to enter the size of their storage facility and estimated energy consumption. The Natural Resources Canada (NRCan) Office of Energy Efficiency surveyed energy usage for 17 dairy processing plants to benchmark total energy usage (NRCan, 2001). It was determined that it was not possible to compare different plants directly because they stored milk on site for a short period of time, stored it at a distribution center, or transported it to retail outlets; therefore, they reported the total plant energy consumption both with or without cold storage data. In this study, we report our data similarly. Energy consumption for cold storage of the NRCan-surveyed plants ranged from a low of 0.0017 kWh/L to a high of 0.0843 kWh/L. We report total plant energy consumption for the simulated plants with cold storage using the highest energy reported in the NRCan report, with a corresponding electricity index of 13.5 kWh/m² per day (1.25 kWh/ft² per day) assigned in the simulator for cold storage. We also report the total plant energy consumption on a cold storage-free basis, with an electricity index of 0.0. The user can provide their own value of the electricity index for their particular method of cold storage. For cold storage of milk solely in the plant, values of the electricity index, with an average value of 0.840 kWh/m² per day (0.078 kWh/ft² per day), found in ASHRAE (2007) for refrigerated warehouses, may be used in the simulator.

Ultrasonic case washers in the cold storage area consume significant amounts of water. It was assumed that 6,000 L/d of water was used for case washing.

Cleaning-In-Place. Little quantitative information on CIP operations is available. This portion of the simulation model is an estimation of the CIP operation developed using the information provided in Eide et al. (2003) and from the dairy industry. Two CIP skids are used in our simulation, one for silos, tanks, and filling machines and the other for the pasteurizers. The cleaning sequences for the 2 skids are as follows:

Skid no. 1 (for milk silos, tanks, and filling machines)

1. Flush with warm water at 45°C for 10 min.
2. Circulate the caustic cleaning solution at 75°C for 10 min.
3. Rinse with water at 45°C for 5 min.
4. Disinfect with hot water at 95°C for 5 min.
5. Gradual cooling with water at 25°C for 10 min.

Skid no. 2 (for pasteurizers)

1. Flush with warm water at 45°C for 10 min.
2. Circulate with caustic cleaning solution at 75°C for 30 min.

3. Rinse with water at 45°C for 5 min.
4. Circulate with acidic cleaning solution at 70°C for 20 min.
5. Rinse with water at 25°C for 15 min.
6. Disinfect with hot water at 95°C for 15 min.

A typical dairy has about 30 cleaning operations a day. To estimate the amount of material and energy used in the operation, each cleaning step was modeled as 1 cycle/d, 260 d/yr. The volumetric flow rate per vessel internal surface area was set at 12.7 L/m²-min. Because the sizing of the equipment is calculated by the program, the amount of water, cleaning solution, steam, and auxiliary power used in the CIP operation can be predicted.

Wastewater Treatment. Wastewater generated from the CIP operations, the ultrasonic case washers, and sludge from the separator is sent to a wastewater treatment site for pretreatment before disposal. In the simulation, the wastewater (influent) stream combined with the recycled sludge stream was sent to the aeration tank for biooxidation of the organic material. The aeration tank was assumed to operate at an average hydraulic residence time of 6 h and an average sludge residence time of 23 h (Petrides et al., 1998). Aeration blowers maintained a minimum diffused air concentration of 20 mg/L. The following stoichiometric reaction was assumed for the degradation of organic material in the waste stream (Santamarina, 1997):

After biooxidation, the waste stream was sent to the clarifier where 99% of the biomass was removed and was concentrated to about 1% wt/wt solids content. The liquid effluent, which contained mostly water, was disposed of as aqueous waste. Seventy-five percent of the sludge stream was recycled back to the aeration tank. The rest was pumped to a belt filter press where it was thickened to 15% (wt/wt) solids content. The removed water, which contained small amounts of biomass and dissolved solids, was sent back to the aeration tank. The concentrated sludge stream was dewatered to a final solids concentration of 35% (wt/wt) using a sludge dryer and was disposed of as solid waste. The wastewater treatment operations are designed to accommodate process wastes only. The water used and wastes generated during milk tanker/truck cleaning and external cleaning of equipment and floors were not modeled in this study and would significantly increase the required plant capacity for wastewater treatment, as would other water use throughout the plant.

Process Data Entry

Right clicking on an icon allows the user to enter operating data, procedure data, and equipment data. Operating data for a heat exchanger, for example, includes information such as temperature and pressure, the type of heating agent used (e.g., steam), and assumption of a value for the heat transfer coefficient. In the procedure data tab, the user indicates if the equipment is operated in a batch or continuous mode and the cycle time. Under the equipment data tab, information on the area available for heat transfer, and the type of heat exchanger (e.g., plate and frame vs. shell and tube) is indicated. The operating data tab allows the user to enter the characteristics of the milk, such as the flow rate, temperature, pressure, physical state, and composition by clicking on the stream arrows that connect 2 different unit operations.

Cost Data

The user may use the costs provided in the simulator or enter those from vendors, or both. In this study, cost data were based on the economic conditions of 2012. Costs of milk, cleaning agents, and other materials were provided from the dairy industry or were estimated. Buildings and associated equipment such as refrigeration were estimated as a separate item. Sanitary construction was assumed for all equipment costs that were obtained from equipment manufacturers, members of the dairy industry, in-house cost data library, and from information found in Dalton et al. (2002), Persson (1987), Jacobs and Criner (1990), and Cole (2004). The installation costs were estimated by composite or Lang cost factors. The Lang factors, which were developed in a method for estimating the total installation costs for plant equipment, are multiplied by the basic equipment costs to account for engineering and construction, piping, electrical, and instrumentation (Ray and Sneesby, 1998; Peters et al., 2003).

The simulator generates reports such as the materials and streams report, an economic evaluation report, cash flow analysis report, itemized cost report, a throughput analysis report, an environmental impact report, an emissions report, an equipment report, a CIP Skid Report and an Input Data Report. Additional reports were added through the addition of Excel spreadsheets to collate the energy data generated from the simulation, such as that for electricity, steam, cooling water and chilled water used in each unit operation, to calculate the GHG emissions for each.

Model Validation and Applications

After creation of the model, data from a fluid milk processing plant in the United States and from the lit-

erature were used to validate the model by comparison of the reported electrical and natural gas energy usages with the values predicted by the model. Data from the model and the literature were converted to SEC for ease of comparison.

The model was also used to demonstrate applications such as calculation of SEC, GHG emissions, and process economics for entire fluid milk processing plants of various sizes and to examine the effect of changes in one of the unit operations, such as the level of percentage regeneration in HTST pasteurization, or the use of total versus partial homogenization, on SEC and GHG. The effects of adjustments in the values of the nonprocess efficiencies, which were set to 25% for electrical usage (Peters et al. 2003) and 20% for natural gas usage (Babcock & Wilcox Company, 2005), on the total plant SEC and GHG emissions were also examined.

RESULTS AND DISCUSSION

To illustrate the base fluid milk process model (Figure 1), a simulation trial was conducted for the 40.0 million L/yr fluid milk processing plant. This model, as well as the other process models discussed in this study, was assumed to operate continuously. Milk was processed for 260 d/yr, 16 h/d, with 8 h/d dedicated to cleaning operations, similar in operation to many dairy plants in the United States. The simulation model applies from storage of the raw milk in silos to cold storage of the packaged product. It was assumed that only whole milk and 40% cream was processed throughout this study, although at the separation step, the operating conditions may be adjusted for a plant processing skim, 1, or 2% milk, or pasteurized cream products. The flow sheet may also be expanded through the addition of tanks or fermentation vessels for manufacture of chocolate milk products and products such as buttermilk. A regeneration of 94% was assumed in the regenerator section of the pasteurizer throughout, unless otherwise noted.

Upon completion of the simulation, an Excel (Microsoft Corp., Redmond, WA) spreadsheet was prepared to automatically extract energy usage data for each of the unit operations that compose the fluid milk process from the itemized cost report of SuperPro Designer (Table 2). The results are reported as obtained from the itemized cost report and were not rounded. Energy usage is reported in terms of the electricity to power the unit operations; steam used for pasteurization, standardization, cream pasteurization, CIP, and wastewater treatment; cooling water used in standardization; and chilled water used in the raw milk section and in milk and cream pasteurization to cool milk after it is pasteurized. These values are considered bare numbers,

Table 2. Simulated annual utility usages for the unit operations in the base fluid milk processing plant with a production rate of 40.0 million L/yr

Section	Electricity (kWh/yr)	Steam (t/yr)	Cooling water (t/yr)	Chilled water (t/yr)
Raw milk section	1,633			6,137
Pasteurization	1,095	372		35,722
Homogenization	219,065			
Standardization	142,787	14	65,988	
Milk packaging	563,861			
Cream pasteurization	10	5		4,825
Cream packaging	15,622			
Cold storage	2,308,800			
CIP ¹	6,842	1,310		
Wastewater treatment	18,067	164		
Total	3,277,822	1,865	65,988	46,684

¹Clean-in-place.

as they are related to energy usage by the unit operations alone.

The annual utility usage data of Table 2 was converted to the primary sources, electrical energy, and natural gas to facilitate calculation of the GHG emissions for each unit operation as reported in Table 3. A 25% allowance (Peters et al., 2003) was first added to the electricity usage estimates of Table 2 to account for nonprocess utility requirements, such as the additional power losses in the electrical step-down transformers and distribution systems, instrumentation systems, plant communication systems, compressed air systems for air-driven controls or motors and blow molding, electrical heat tracing of piping exposed to cold external temperatures throughout the plant, building lighting, office plug loads, and office space conditioning. The allowance may be assigned from 10 to 25%, depending on the efficiency of electrical processes in the plant.

The electrical energy used to generate the steam was taken into account using the conversion factor 0.55 kWh/1,000 kg of steam, provided by vendors, for an on-site natural gas steam-generating system. This factor may be adjusted depending on the user's natural gas system. A 20% allowance was added to the natural gas use to account for the inefficiency of the conversion of natural gas energy to steam energy in the boiler. This value was based on discussions with various boiler manufacturers and will vary depending on the design and operation of a specific boiler. Additional information on boiler efficiencies is found in Babcock & Wilcox Co. (2005). The quantity of cooling water used from Table 2 was converted to kilowatt hours using the conversion factor 0.00011 kW/kg of cooling tower water provided by a vendor for a cooling tower water system processing 9,720 L of water/min that required approximately 50 kWh for the cooling tower fans and an additional 15 kWh for the cooling water pumps and water treatment system. The quantity of chilled water

used was first converted to energy units using the glycol energy-to-mass factor (5.5046 kcal/kg) from SuperPro. The result was converted to tons of refrigeration (**TR**), using the conversion factor 3,023 kcal/TR. The result was multiplied by the factor 2 kWh/TR to report the quantity of chilled water in terms of electrical usage.

The GHG emissions associated with each of the unit operations are also shown in Table 3 and were calculated using the energy data for the unit operation and the conversion factors given in Deru and Torcellini (2007). The source emission factor for CO_{2e} used for electricity was 1.67 pounds (0.758 kg) of CO_{2e}/kWh. The source emission factor for CO_{2e} used for natural gas was 146.6 pounds of CO_{2e}/million BTU (0.06312 kg of CO_{2e}/MJ) of natural gas. The percentage contribution of each unit operation to total GHG emissions from the fluid milk process was calculated in 2 ways. In the first, a high value of the electricity index (13.5 kWh/m² per day) was used in the simulator for a plant with large energy usage attributed to cold storage (NRCAN, 2001). In the second, the contribution of cold storage to total GHG emissions was omitted.

Greenhouse gas emissions were predicted by the simulation model as ranging between 90.8 g of CO_{2e}/kg of milk, if cold storage with significant energy usage was assumed, and 36.2 g of CO_{2e}/kg milk if cold storage was not considered in the model. Electricity usage for cold storage of milk contributed to 60.2% of GHG emissions for the simulated plant, followed by milk packaging (14.7%), homogenization (5.7%), and standardization (4.0%). Greenhouse gas emissions from electricity usage totaled 81.0 g of CO_{2e}/kg of milk. Steam required for CIP operations and milk pasteurization were the largest consumers of natural gas, contributing 7.8 and 4.9%, respectively, to total GHG emissions. Most of the chilled water was used by the milk and cream pasteurization processes and was assumed to consume electricity. Greenhouse gas emissions from natural gas

Table 3. Conversion of simulated annual utility usages of Table 2 to the primary energy sources electricity and natural gas and greenhouse gas (GHG) emissions for the unit operations in a base fluid milk processing plant with a production rate of 40.0 million L/yr

Section	Electricity + 25% (kWh/yr)	Steam (kWh/yr)	Natural gas +20% (BTU/yr) ¹	Cooling water (kWh/yr)	Chilled water (kWh/yr)	GHG ² emissions (kg of CO _{2e} /yr) ³	GHG (g of CO _{2e} / kg of milk)	% GHG, with cold storage	% GHG, cold storage free
Raw milk section	2,041				22,352	18,500	0.5	0.5	1.3
Pasteurization	1,369	205	1,180,638,720		130,107	178,600	4.5	4.9	12.3
Homogenization	273,831					207,900	5.2	5.7	14.3
Standardization	178,484	8	44,432,640	7,272		144,000	3.6	4.0	9.9
Milk packaging	704,826					535,000	13.3	14.7	36.9
Cream pasteurization	13	3	15,868,800		17,574	14,400	0.4	0.4	1.0
Cream packaging	19,578					14,900	0.4	0.4	1.0
Cold storage ⁴	2,886,000					2,190,700	54.8	60.2	
CIP ⁵	8,553	722	4,157,625,600			284,100	7.1	7.8	19.6
Wastewater treatment	22,584	90	520,496,640			51,900	1.3	1.4	3.6

¹BTU = British thermal unit. Equivalent values in megajoules per year are given in Table 4.

²GHG = greenhouse gas.

³CO_{2e} = CO₂ equivalents.

⁴An electricity index of 13.5 kWh/m² per day was used in the simulator for cold storage on site and in a distribution center. For on-site cold storage, 0.840 kWh/m² per day (ASHRAE, 2007) may be used.

⁵Clean-in-place.

Table 4. Energy and specific energy consumption (SEC) associated with electricity, natural gas, cooling water, and chilled water use for each unit operation in the fluid milk processing plant with a production rate of 40.0 million L/yr

Section	Electricity (MJ/yr)	Steam, electrical (MJ/yr)	Steam, natural gas (MJ/yr)	Cooling water (MJ/yr)	Chilled water (MJ/yr)	Energy (MJ/yr)	SEC (MJ/kg)	Energy use ¹ (%)
Raw milk section	7,350				80,500	87,850	0.002	0.4 (0.8)
Pasteurization	4,930	700	1,245,600		468,400	1,719,630	0.04	7.9 (15.3)
Homogenization	985,800					985,800	0.03	4.6 (8.8)
Standardization	642,500	30	46,900	26,200		715,630	0.03	3.3 (6.4)
Milk packaging	2,537,400					2,537,400	0.06	11.7 (22.6)
Cream pasteurization	50	10	16,700		63,300	80,060	0.00	0.4 (0.7)
Cream packaging	70,500					70,500	0.00	0.3 (0.6)
Cold storage ²	10,389,600					10,389,600	0.26	48.0 (0)
CIP ³	30,800	2,600	4,386,500			4,419,900	0.11	20.4 (39.3)
Wastewater treatment	81,300	330	549,200			630,830	0.02	2.9 (5.6)
Total energy	14,750,230	3,670	6,244,900	26,200	612,200	21,637,100		
SEC	0.37	0.00	0.16	0.00	0.02	0.54	0.54	

¹Values in parentheses are on a cold-storage free basis.

²An electricity index of 13.5 kWh/m² per day was used in the simulator for cold storage on site and in a distribution center. For on-site cold storage, 0.840 kWh/m² per day (ASHRAE, 2007) may be used.

³Clean-in-place.

usage were predicted as 9.8 g of CO_{2e}/kg of milk. The simulation was also repeated using the average value of the electricity index: 0.840 kWh/m² per day (ASHRAE, 2007) for a refrigerated warehouse. The GHG emissions from cold storage were then 4.7 g of CO_{2e}/kg of milk, with a percentage contribution to total GHG emissions of 11.8%.

The energy data reported in Table 3 were also used to calculate the energy usage and the SEC of each unit operation, and the total SEC of the process as shown in Table 4. In addition to the GHG emissions calculated in Table 3, SEC, calculated for each unit operation, is useful for comparing the energy usage of the unit operations and for comparing the energy efficiencies across different fluid milk processing plants (Xu and Flapper, 2009). In facilities with a high cold storage energy usage, energy consumption decreases in the following order: cold storage, CIP, milk packaging, and milk pasteurization. If cold storage is not considered, CIP operations are the most energy intensive. For a refrigerated warehouse with an electricity index of 0.840 kWh/m² per day (ASHRAE, 2007), the percentage energy contribution of cold storage is then 7.7%, with CIP operations the most energy intensive unit operation.

The economic evaluation report provides a summary of the capital costs of the equipment, the operating costs, and unit operating costs for conducting an economic analysis of the process. The yearly operating costs for the base 40.0 million L/yr plant are \$24,352,000. Table 5 provides more detailed information on the costs of utilities, raw materials, labor, and waste disposal costs. The utilities do not include the capital costs associated with their generation. Capital depreciation is listed separately. The other facility-dependent costs include maintenance, which is 3% of capital costs; insurance, which is 0.8% of capital costs; and factory expenses, which are 0.75% of capital costs.

Model Validation

Model validation is necessary to ensure its accuracy for each section of a process or over the entire process. Dairy processing plants are metered to record data on electricity use, fuel use, water use, and wastewater. This information can be used to benchmark the entire plant, but not the individual processes. Xu and Flapper (2009) analyzed energy data of plants both nationally and internationally and found that the SEC of individual plants ranged from 0.2 to 12.6 MJ/kg of fluid milk produced. Plants with low SEC are more energy efficient than plants with large SEC. For plants in the United States, the US Department of Energy Industrial Assessment Report (US DOE, 2010) reported values of SEC ranging from 0.2 to 6.0 MJ/kg. In this study, SEC

was 0.54 MJ/kg of milk (Table 4) for the base fluid milk plant processing 40.0 million L/yr, which is in the lower end of the range of SEC reported for plants in the United States. If cold storage is not considered in the calculation of SEC, then SEC is as low as 0.27.

The performance of the simulation model in predicting benchmark energy usage data at various stages of milk processing reported by NRCAN (2001) was also examined. Benchmarking values for the processes in the NRCAN study were established from the 10th percentile of the plants in a survey sample having the lowest values of SEC for milk receiving, separation, homogenization/pasteurization, filling, and CIP. The following SEC (in MJ/kg) were reported: 0.018 (milk receiving), 0.018 (separation), 0.189 (homogenization/pasteurization), 0.036 (filling/packaging), and 0.108 (CIP). An overall SEC of 0.1183 kWh/L of milk (0.4183 MJ/kg of milk) was reported for the entire plant. For comparison, the SEC values (Table 4) calculated by the simulation model (in MJ/kg) were 0.002 (milk receiving), 0.017 (separation), 0.07 (homogenization/pasteurization), 0.06 (filling/packaging), and 0.11 (CIP), respectively, with an overall SEC of 0.27 MJ/kg, excluding cold storage. All of the simulated values for the individual processes were within the ranges reported for the 17 plants surveyed in the Canadian study. The NRCAN (2001) reported that the range of SEC for pasteurization/homogenization for the 17 plants ranged from 0.0691 to 0.9882 MJ/kg. The value of SEC from this study (0.07 MJ/kg) is in agreement with the lowest value in the range for pasteurization/homogenization of the NRCAN study and below the 10th percentile of values. The large range of SEC values for pasteurization/homogenization reported by NRCAN reflect that steam was generated not only by natural gas in the 17 plants that were sampled, but also by other fuel sources such as bunker carbon, light fuel oil, and propane. In addition, boiler efficiencies and the percentage regeneration used in the regeneration section of the pasteurizers was not reported and would be expected to vary from plant to plant. Greenhouse gas emissions were not reported in the NRCAN (2001) report.

The performance of the process simulation model in predicting energy consumption data (Table 6) for several production scenarios in pasteurized milk production (Nicol et al., 2005) was also determined. The assumed pasteurization temperature and holding time were not reported. Also, the reported energy associated with CIP operations was approximately 80% lower than that reported by NRCAN (2001), Xu and Flapper (2009), and the Innovation Center for US Dairy (Tomasula and Nutter, 2011) and was not simulated.

The pasteurization/homogenization scenarios were simulated using the same production rate of 24,000 L of

Table 5. Annual operating costs for the base fluid milk plant producing 40.0 million L/yr of whole milk

Item	Unit cost (\$)	Amount/yr	\$/yr
Raw materials			
Milk	0.36	39,998,961 kg	14,417,860.68
Oxygen	0.00	500 kg	0.00
Resin for gallon jugs	2.54	597,735 kg	1,515,448.47
Paper pint containers for cream	0.02	1,566,153	31,323.06
Water		10,751,254 kg	3,795.19
Water (CIP) ¹	0.00	8,697,016 kg	3,070.05
Wastewater treatment		502,499 kg	177.38
Cold storage		1,551,739 kg	547.76
Air		1,339,510 kg	0.00
Caustic cleaner	0.01	1,687,072 kg	22,905.32
Acid cleaner	0.05	587,822 kg	30,374.05
Total raw materials			16,021,706.77
Labor	40.00	124,800 h	4,992,000.00
Waste treatment disposal			
Waste costs			
Solid waste	0.05	85,746 kg	
Aqueous waste		12,826,199 kg	
Total waste treatment			4,287.00
Utilities			
Electricity	0.09	3,277,823 kWh	196,669.38
Heat transfer agents		114,537,482 kg	67,595.00
Steam	12.00	1,865 t	22,386.00
Cooling water	0.07	65,988 t	4,619.19
Glycol	0.35	46,684 t	16,339.27
Total utilities			240,014.00
Depreciation			2,127,000.00
Other facility-dependent costs			968,000.00
Total			24,352,000.00

¹CIP = clean-in-place.

milk/h, 16 h of production/d, with 8 h of cleaning, and a boiler efficiency of 85%. The pasteurization temperature of 77°C and holding time of 22 s used throughout our study was assumed for the simulations. The flow sheet for the simulation process model with partial homogenization is shown in Figure 2.

Overall, good agreement between the plant energy values (Nicol et al., 2005) and those predicted by the model for the thermal phases of pasteurization and chilled water production were noted for all processing scenarios, correctly showing the effect that increasing percentage regeneration has on reducing thermal energy, with an average absolute deviation of 1.9 MJ/kL, and chilled water use, with an average absolute deviation of 4.3 MJ/kL. The predicted values of electricity were also in good agreement, with an average absolute deviation of 1.2 MJ/L. The reduction in electricity usage during homogenization was also correctly predicted when the partial homogenizer replaced the homogenizer, with an average absolute deviation of 4.1 MJ/kL.

In a final test of the simulator, utility data from a large dairy processing plant were used to calculate the plant SEC for electrical and natural gas usage and compared with that of the simulator. Using data for 4 wk of a run producing 16.51×10^6 kg of whole milk, the electrical usage of the plant was 1.418×10^6 kWh

and the natural gas usage was 1.721×10^6 MJ (1.632×10^9 BTU). The plant was not in operation for 2 d of each week. The calculated SEC for electricity was 0.31 MJ/kg and that for natural gas was 0.17 MJ/kg, with a total SEC for the plant of 0.48 MJ/kg, which is considered an efficient plant by the criteria of Xu and Flapper (2009). The SEC for electricity of the plant (0.31 MJ/kg) was lower than that predicted by the simulator (0.38 MJ/kg), which increases the predicted process energy by a 25% allowance (Peters et al., 2003) to account for miscellaneous electrical plant energy. If a 10% allowance is used in the simulator instead, then good agreement is obtained with the plant data. The need for the lower factor is an indication that the plant initiated energy-saving measures. The SEC for natural gas usage predicted by the simulator was 0.09 MJ/kg, whereas that of the plant was 0.17 MJ/kg. Natural gas is most likely used for other plant operations to heat water not accounted for in the simulator, such as in the milk receiving area, and for cleaning milk tankers and the surrounding area and the floors of the plant.

The fluid milk model also predicts the amount of water used in each unit operation, giving users the option of designing strategies that minimize water use in processing. Unfortunately, process water data was not available in the literature or from industry sources to

Table 6. Comparison of simulated model results (Model) with pasteurized milk production scenarios from Nicol et al. (2005; Nicol) for a plant with a production rate of 24,000 L/h and run time of 16 h/d¹

Item	Production scenario ²							
	%R = 90%		%R = 92%		%R = 95%		%R = 90%	
	Nicol	Model	Nicol	Model	Nicol	Model	Nicol, HPH	Model, HPH
Thermal (MJ/kL)	28.9	31.8	23.3	22.3	14.5	16.3	28.9	31.8
Chilled water (MJ/kL)	33.2	37.5	27.5	31.7	18.8	23.1	33.2	37.3
Electricity (MJ/kL)	18.2	17.1	18.2	17.0	18.2	17.0	21.7	21.6

¹Data apply from between the pasteurizer balance tank to the packaging machine balance tank. Homogenization pressure = 130 bar (13 MPa) unless otherwise indicated.
²%R = percentage regeneration; PH = partial homogenization; HPH = high pressure homogenization = 160 bar (16 MPa).

validate the performance of the model. Water usage data for entire dairy plants was available, though, and can range from 1.02 L of water/L of milk processed to approximately 3 L of water/L of milk processed (personal communications with dairy plant managers). For a plant processing 40.0 million L/yr of milk, the simulation model predicted that 0.3 L of water was used for CIP and case washing per liter of milk processed. Including the utility water used in cooling and chilling operations (Table 2), which totals 112,672,000 kg and is recovered and reused in the plant, and adding about 5% make-up water to account for losses during the recovery/reuse operations, would only increase simulator-predicted usage of water to 0.4 L of water/L of milk processed. The simulation model currently does not account for cleaning of milk tankers or external equipment and floor cleaning that occurs in a dairy plant. In future iterations of the simulation model, either unit operation models may be developed to represent these washing and cleaning activities or a factor could be added to the process water usage calculated by the simulator to account for washing and cleaning. The heavy use of water indicates several opportunities for development of best practices for decreasing water use for cleaning and washing throughout the plant. Several water efficiency measures for dairy processing plants are discussed in Brush et al. (2011).

Model Applications

For the fluid milk process, the prediction of SEC, GHG emissions, and process economics is affected by the flow rate of the process and the electrical and fuel energy used in the process. The electrical and fuel energy usage depends on the energy used to directly process milk and the non-process-related activities encountered in a milk processing plant. The use of the simulator for prediction of SEC, GHG emissions, and process economics is shown in this section and demonstrates the flexibility of the simulator for assisting processors in benchmarking their current operations and then improving the energy efficiency of their plants.

Simulation of Small, Medium, and Large Dairy Plants. Dairy plant models were constructed for a medium (113.6 million L/yr) and a large (227.1 million L/yr) plant to determine if plant size affected energy usage in terms of SEC, GHG emissions, and processing costs, compared with the 40.0 million L/yr base plant. In the United States, plants producing <75.7 million L of milk/yr are considered small plants, plants producing between 75.7 and 151.4 million L of milk/yr are considered medium-sized plants, and plants producing >151.4 million L of milk/yr are considered large plants. The simulations apply from storage of the

Table 7. Allocation of electricity and fuel to total energy and total specific energy consumption (SEC) for 3 facilities¹

Facility	Electricity (kWh/yr)	SEC for electricity (MJ/kg)	Natural gas (MJ/yr)	SEC, natural gas (MJ/kg)	Total energy (MJ/yr)	Total SEC (MJ/kg)
40.0 × 10 ⁶ L/yr	4,275,000 (1,390,000)	0.38 (0.13)	6,245,000	0.16	21,637,000 (11,248,000)	0.54 (0.28)
113.6 × 10 ⁶ L/yr	12,060,000 (3,935,000)	0.38 (0.13)	14,040,000	0.12	57,457,000 (28,207,000)	0.51 (0.25)
227.1 × 10 ⁶ L/yr	24,115,000 (7,865,000)	0.38 (0.13)	24,461,000	0.11	111,278,000 (52,778,000)	0.49 (0.23)

¹Evaluated with cold storage and on a cold storage-free basis (the latter values in parentheses).

²An electricity index of 13.5 kWh/m² per day was used in the simulator for cold storage on site and in a distribution center. For on-site cold storage, 0.840 kWh/m² per day (ASHRAE, 2007) may be used.

milk in silos to cold storage of the packaged product at the plant.

The predicted annual total energy (MJ/yr) for the small, medium, and large facilities, with the individual contributions from process electricity (kWh/yr) and natural gas usage (MJ/yr) are reported in Table 7. The corresponding total energy and electricity for plants on a cold storage-free basis are also reported. The data were converted to SEC to facilitate comparison of the plants.

The values of the total SEC show a small decrease as plant size was increased. With increasing plant size from 40.0 to 113.6 million L/yr, SEC decreased by 6%. The SEC decreased only 4% when plant size was increased from 113.6 to 227.1 million L/yr, but decreased by 9% when plant size increased from 40.0 million to 113.6 million L/yr, showing a small improvement in energy efficiency for plants of larger size. Whereas the SEC for the electricity-dependent unit operations of all plants was constant at 0.38, the SEC for the natural gas-dependent operations, which are mainly CIP operations and milk and cream pasteurization, decreased by 0.16, 0.12, and 0.11, respectively, with increasing plant size, indicating a reduced use of steam as plant size became larger.

To investigate which operation had reduced energy usage as plant size was increased, SEC was recalculated eliminating CIP in the calculation. The SEC for the milk and cream pasteurization processes for all plants was 0.033, indicating that SEC for CIP operations decreased with increasing plant size and that the CIP operation was most efficient for the largest plant. In the simulation models, the volumetric flow rates for the cleaning solutions and rinse water in each plant were assumed to be the same. The amount of water used is proportional to the volumetric flow rate/internal surface area of the equipment. As the plants increase in size, the volume of the equipment that is cleaned increases but there is a smaller rate of change in the internal surface area as the volume increases. Thus, the

amount of water or cleaning solution needed decreases as plant size increases.

Using the energy consumption data of Table 7, the GHG emissions for the 113.6 million and 227.1 million L/yr plants were calculated and compared with those for the 40.0 million L/yr plant, as shown in Table 8. For all plants, the GHG emissions associated with the unit operations are the same as those reported for the 40.0 million L/yr plant shown in Table 3, with the exception of the value reported for CIP operations (data not shown). The carbon footprint of milk decreased slightly with increasing plant size, from a value of 91.0 g of CO_{2e}/kg of milk for the smallest plant to a value of 87.5 g of CO_{2e}/kg of milk for the larger plant, reflecting the impact of the more efficient use of natural gas energy in CIP operations as plant size increased (Table 7). The values for the carbon footprint of milk are in good agreement with the average value of 96 g of CO_{2e}/kg of packaged milk (Tan et al., 2011; Thoma et al., 2012) for milk processing and packaging, demonstrating the predictive ability of the simulator. Recalculating the carbon footprint of milk by neglecting on-site cold storage shows that the plant total GHG emissions decrease by about 60% for all plants to a value of 36.2 g of CO_{2e}/kg of milk for the smallest plant.

A summary of the economic analysis for the plants generated by the economic evaluation report of the software is shown in Table 9. The capital costs include all costs related to the equipment and the processing plant facility but not additional facilities that might be on site. Other costs such as start-up costs and costs of capital are not included. The annual operating costs are the sum of the costs of utilities, waste treatment, raw materials, labor, and other facility-dependent costs. Costs related to transportation, advertising, failed product disposal, and laboratory analyses, were not included in this analysis. The unit production costs are the sum of the operating costs and capital depreciation divided by the filled gallon entities.

Table 8. Greenhouse gas (GHG) emissions for 3 facilities with cold storage and on a cold storage-free basis^{1,2}

Facility	CO _{2e} (kg/yr)	GHG from electricity (g of CO _{2e} /kg of milk)	GHG from natural gas (g of CO _{2e} /kg of milk)	CO _{2e} (g/kg of milk)	CO _{2e} (g/gal of milk)
40.0 × 10 ⁶ L/yr	3,633,000 (1,447,000)	81.0 (26.4)	9.8	90.8 (36.2)	344 (137)
113.6 × 10 ⁶ L/yr	10,023,000 (3,867,000)	80.7 (26.4)	7.8	88.6 (34.2)	335 (129)
227.1 × 10 ⁶ L/yr	19,815,000 (7,502,000)	80.7 (26.4)	6.8	87.5 (33.1)	331 (126)

¹CO_{2e} = CO₂ equivalent; gal = gallon of whole milk = 3.785 L of whole milk.

²Values in parentheses are on a cold storage-free basis.

The unit production costs for the 40.0 million L/yr plant (\$2.36/entity) are greater than those for the 113.6 million L/yr (\$2.02/entity) and 227.1 million L/yr (\$1.91) plants. Economy of scale effects are demonstrated with decreased labor, equipment, and facility costs as a percentage of plant capacity. However, as shown earlier in Tables 7 and 8, the scale of the plant has little effect on energy usage or the carbon footprint of milk per kilogram of milk produced.

Effect of Level of Percentage Regeneration. The level of percentage regeneration is known to affect the amount of the heating and cooling energy associated with pasteurization that is saved. To demonstrate its effects, the 40.0 million L/yr plant was simulated with successive changes in the levels of percentage regeneration to 90, 92, 94, 95, and 96%. The results are reported in Table 10. Increasing levels of percentage regeneration showed a small, insignificant decrease in the amount of electricity associated with boiler production of steam. However, natural gas use in pasteurization decreased from 1,940,000 to 807,000 MJ/yr as percentage regeneration was increased from 90 to 96%. Chilled water use decreased from 709,000 to 317,000 MJ/yr over the same increase in percentage regenera-

tion. Overall, the total energy used in pasteurization showed a 57% decrease in energy use from 2,654,000 to 1,129,000 MJ/yr, with SEC decreasing from 0.07 to 0.03 MJ/kg and the carbon footprint of milk from 6.8 to 3.0 g of CO_{2e}/kg of milk.

As shown earlier, the model was used to predict the thermal and electrical energy when partial homogenization is used (Table 6). Even though partial homogenization lowers electricity use of the homogenization step by 82%, steam consumption increases by 77% because milk enters the second regeneration section at lower temperature. Full homogenization heats the milk stream to a higher temperature when conventional milk processing is used. In comparison with the 40.0 million L/yr base plant with full homogenization, the decrease in electricity with partial homogenization results in a 5.4% decrease in the carbon footprint of milk from 90.8 (Table 3) to 87.1 g of CO_{2e}/kg of milk. Utility costs are also reduced with partial homogenization. The costs of utilities with full homogenization are \$240,014/yr and are \$231,813/yr with partial homogenization.

Alternatives to HTST Pasteurization. Although increasing the percentage regeneration of the pasteurizer from 90 to 96% resulted in significant reductions

Table 9. Summary of economic analysis for the production of fluid milk for small, medium, and large processing plants

Item	Processing plant		
	40.0 million L/yr	113.6 million L/yr	227.1 million L/yr
Filled gallon entities (no.)	10,305,783	29,161,110	58,322,220
Capital costs (\$)	21,266,000.00	28,124,000.00	39,674,000.00
Equipment	5,633,000.00	9,062,000.00	14,837,000.00
Operating costs ¹ (\$)	22,226,000.00	56,230,000.00	107,237,000.00
Utilities	240,000.00	664,000.00	1,316,000.00
Waste treatment	4,000.00	12,000.00	24,000.00
Raw materials	16,022,000.00	45,288,000.00	90,530,000.00
Labor	4,992,000.00	8,986,000.00	13,562,000.00
Other facility	968,000.00	1,280,000.00	1,805,000.00
Capital depreciation (\$)	2,127,000.00	2,812,000.00	3,967,000.00
Unit production costs (\$)	2.36/MP entity ²	2.02/MP entity	1.91/MP entity

¹Operating costs do not include depreciation. Depreciation is reported as a separate item.

²MP entity = 1 gallon of whole milk packaged = 3.785 L of whole milk packaged.

Table 10. Effect of percentage regeneration (%R) on electricity associated with boiler production of steam, fuel, chilled water, total energy use, specific energy consumption (SEC), and greenhouse gas (GHG) emissions in pasteurization for a 40.0 million L/yr plant

Item	%R				
	90%	92%	94%	95%	96%
Electricity, steam (MJ/yr)	1,150	920	700	590	480
Natural gas (MJ/yr)	1,940,000	1,560,000	1,245,600	998,000	807,000
Chilled water (MJ/yr)	709,000	577,000	468,300	382,000	317,000
Total energy (MJ/yr)	2,650,000	2,140,000	1,714,600	1,380,000	1,130,000
SEC (MJ/kg)	0.07	0.05	0.04	0.04	0.03
GHG emissions (g of CO _{2e} /kg of milk) ¹	6.8	5.5	4.4	3.6	3.0

¹CO_{2e} = CO₂ equivalent.

in energy use and a 56% reduction in g of CO_{2e}/kg of milk (Table 10), HTST pasteurized milk requires cold storage, which has been shown through the simulation studies here to contribute up to 60.8% to total plant GHG emissions (Table 3) and 49.3% to total energy use of the process (Table 4). Milk pasteurized using alternative pasteurization methods, described in detail in Tomasula and Nutter (2011), such as UHT milk pasteurization (Datta et al., 2002), does not require cold storage if packaged aseptically. Although UHT pasteurization consumes more energy than HTST pasteurization (Juriaanse, 1999), a net energy savings would be realized, as electrical energy to power cold storage at the plant or at distribution and retail sites would be eliminated (Chandarana et al., 1984).

Microfiltration (Hoffman et al., 2006; Kulozik, 2007; Tomasula et al., 2011) is another alternative pasteurization method that is used as a unit operation before HTST pasteurization to remove the somatic cells, microflora, and pathogens, if present, in milk. Milk microfiltration is currently used in several countries and requires electrical energy to operate. Microfiltration equipment must also be cleaned intensely to remove a milk fouling layer if present and to prevent microbial growth on the membrane. The process simulator would allow processors to evaluate the feasibility of installation of microfiltration units into existing fluid milk processing lines to evaluate GHG emissions, increases in energy usage, if any, water use, and costs.

Other alternative pasteurization methods such as pulsed electric fields and high-pressure processing (Datta et al., 2005; Toepfl et al., 2006) require lower pasteurization temperatures than HTST pasteurization. At the current time, these methods are still under investigation and not yet scalable for use in large fluid milk processing facilities. The process simulator presented in this study will be a useful tool for investigating the feasibility of these and other nonthermal methods in a fluid milk processing line.

The GHG emissions, energy use, and costs associated with aseptic packaging may also be evaluated using

the simulator. However, a model for aseptic packaging needs to be developed. Alternative processing methods also may require new or significant modifications of CIP procedures now used with HTST pasteurization processing, which may be explored with modifications to the simulator.

Impact of Nonprocess Efficiencies. The simulator assumes a boiler efficiency of 80%, which may be adjusted to determine the effect of boiler efficiency on the total energy used to process milk. A factor of 25%, which may also be adjusted, was also added to the simulated electrical bare energies of the unit operations to account for nonprocess electrical requirements in the plant. Adjustment of these factors in the simulator would allow a processor to determine their effect on SEC and GHG emissions as well as the cost savings (not shown) if best practices are implemented to reduce energy consumption.

Table 11 shows the impact of various combinations of boiler efficiencies for steam production and nonprocess electrical requirements compared with the factors used in the simulator. If boiler efficiency is held constant at 80% (20% factor) and the electricity factor is varied from 0 to 25%, total energy consumption of the plant increases from 18,138,000 to 21,637,000 MJ/kg of milk (an increase of 19%). The carbon footprint of milk then increases from 74 to 91 g of CO_{2e}/kg of milk, an increase of 23% and an indication that reducing nonprocess electrical energy usage through implementation of best practices will have a large impact on reducing GHG emissions. For example, if nonprocess plant electrical energy is reduced from 25 to 15% for the 40.0 million L/yr plant, GHG emissions/yr for the plant would be reduced by about 233,000 kg of CO_{2e}/yr.

The effects of changes in boiler efficiency on GHG emissions are weaker than that of improvements in nonprocess electrical energy use. Increasing boiler efficiency from 80 to 90%, with changes in the boiler efficiency factor from 20 to 10% while holding the allowance for nonprocess electrical energy at 25%, resulted in a decrease in plant energy from 21,637,000 to 21,116,000

Table 11. Effect of the values of the nonprocess factors for electricity usage and boiler efficiency on total process energy, specific energy consumption (SEC), and greenhouse gas (GHG) emissions for the base 40.0 million L/yr plant

Electricity factor (%)	Natural gas (%)	Total energy ($\times 1$ million MJ/yr)	kg of CO _{2e} ¹ ($\times 1$ million)	GHG contribution from electricity (g of CO _{2e} /kg of milk)	GHG contribution from natural gas (g of CO _{2e} /kg of milk)	SEC (MJ/kg)	Total GHG (g of CO _{2e} /kg of milk)
25	20	21.637	3.633	81	10	0.54	91
0	20	18.687	3.000	65	10	0.45	75
5	20	19.227	3.080	67	10	0.48	77
10	20	19.867	3.280	72	10	0.50	82
15	20	20.457	3.400	75	10	0.51	85
20	20	21.047	3.520	78	10	0.53	88
40	20	23.407	4.000	90	10	0.59	100
50	20	24.587	4.280	97	10	0.62	107
25	0	20.596	3.600	81	9	0.54	90
25	10	21.116	3.600	81	9	0.53	90
25	30	22.157	3.680	81	11	0.55	92
25	40	22.678	3.720	81	12	0.57	93

¹CO_{2e} = CO₂ equivalent.

MJ/kg, a decrease in energy of 2% with a decrease in GHG emissions from 91 to 90 g of CO_{2e}/kg of milk, or approximately 33,000 kg/yr.

Tan et al. (2011) recommended many strategies to reduce nonprocess electrical and fuel energy use and to lower GHG emissions. These include improvements to reduce natural gas consumption of a boiler, which would affect the value of the boiler efficiency factor in the simulator, or improvements to reduce electricity consumption, such as operating or reducing the power level of electric motor drives that affect unit operations such as homogenization, cold storage, and packaging. Other energy savings opportunities for steam systems, motor systems, compressed air systems, and pumps in dairy plants are discussed in Brush et al. (2011).

Various alternative energy management systems such as solar energy, cogeneration, heat pumps, and geothermal energy, as discussed in Tomasula and Nutter (2011) and Brush et al. (2011), have already been installed in many dairy plants throughout the United States. The process simulator may be used to conduct feasibility testing of integration of these systems to a benchmarked facility to determine cost savings relative to a benchmarked process.

Strategies for CIP Operations. As shown in Tables 3 and 4, CIP processes contribute significantly to GHG emissions and energy usage of fluid milk processing plants. Several alternatives to conventional CIP operations that may lower the energy associated with CIP operations are discussed in Brush et al. (2011). Van Asselt et al. (2002) and Alvarez et al. (2010) demonstrated that critical analysis of CIP operations through monitoring and installation of sensors can significantly shorten cleaning times and reduce energy, wastewater volume, and detergent volume, thus allowing increases in processing time and production. Eide et al. (2003)

showed that enzyme-based cleaning, one-phase alkaline cleaning, and membrane filtration reduced energy use compared with conventional CIP. Enzyme-based cleaners can reduce the chemical load of cleaning effluents in CIP (Graßhoff, 2002) and the environmental impacts contributing to eutrophication. Through development of suitable models, the fluid milk process simulator may be used to evaluate proposed alternatives to CIP as part of the fluid milk process model developed here.

CONCLUSIONS

A computer model for prediction of the energy use, GHG emissions, and costs of the fluid milk process was developed. This is a useful tool for processors to benchmark their current operations, regardless of plant size, to test the cost effectiveness of process and non-process-related plant upgrades for lowering energy use and CO_{2e} emissions and to test the effect on whole plant energy usage and CO_{2e} emissions of the addition of new technologies to an existing milk process. The simulator was validated by comparison of simulation results from literature and industry data. The model-predicted carbon footprint of milk was 91 g of CO_{2e}/kg of milk, which is within 5% of the industry-reported value of 96 g of CO_{2e}/kg of packaged milk obtained by LCA. The model also calculates the water used in each step of the fluid milk process but could not be validated due to a lack of data. This model is available upon request from the authors for educational purposes or for noncommercial use. It is available for download from the website http://www.ars.usda.gov/main/site_main.htm?modecode=19-35-47-00. The model can be viewed and examined using the free evaluation version of SuperPro Designer, which can be downloaded from <http://www.intelligen.com>.

ACKNOWLEDGMENTS

We thank Gail Barnes, formerly of the Innovation Center for US Dairy (Rosemont, IL), and Clay Detlefsen of the International Dairy Foods Association (Washington, DC) for their support of this project; members of the Dairy Plant Smart team for beta-testing the simulation model and their suggestions for its improvement; and the dairy processors who shared their operating data to validate the model. We also thank Demitri Petrides (Intelligen Inc., Scotch Plains, NJ) for reviewing the manuscript.

REFERENCES

- Alvarez, N., G. Daufin, and G. Gésan-Guiziou. 2010. Recommendations for rationalizing cleaning-in-place in the dairy industry: Case study of an ultra-high temperature heat exchanger. *J. Dairy Sci.* 93:808–821.
- ASHRAE (American Society of Heating, Refrigerating and Air-Conditioning Engineers). 2007. 2007 ASHRAE Handbook: Heating, Ventilating, and Air-Conditioning Applications (I-P ed.). Knovel Corp., New York, NY.
- Babcock & Wilcox Company. 2005. *Steam: Its Generation and Use*. 41st ed. Babcock & Wilcox Company, New York, NY.
- Brush, A., E. Masanet, and E. Worrell. 2011. Energy efficiency improvement and cost saving opportunities for the dairy processing industry. An ENERGY STAR® Guide for Energy and Plant Managers. Lawrence Berkeley National Laboratory, Berkeley, CA. Sponsored by the US Environmental Protection Agency. Accessed Aug. 23, 2012. http://www.energystar.gov/ia/business/industry/downloads/Dairy_Guide_Final.pdf.
- Cashman, S., K. Dick, D. Przybylo, and W. Walter. 2009. Charting the course for sustainability at Aurora Organic Dairy. Report No. CSS09-03. University of Michigan, Ann Arbor.
- Chandarana, D. I., B. C. Frey, L. E. Stewart, and J. F. Mattick. 1984. UHT milk processing—Effect on process energy requirements. *J. Food Sci.* 49:977–978.
- Cheng, H., and A. Friis. 2007. Operability and flexibility of a milk production line. *Food Bioprod. Process.* 85:372–380.
- Cole, R. A. 2004. Cold storage warehouses—An engineering overview. Accessed Aug. 23, 2012. <http://seagrant.uaf.edu/map/workshops/cold-storage/Cole.pdf>.
- Dalton, T. J., G. K. Criner, and J. Halloran. 2002. Fluid milk processing costs: Current state and comparisons. *J. Dairy Sci.* 85:984–991.
- Datta, N., A. J. Elliott, M. L. Perkins, and H. C. Deeth. 2002. Ultra-high-temperature (UHT) treatment of milk: comparison of direct and indirect modes of heating. *Aust. J. Dairy Technol.* 57:211–227.
- Datta, N., M. G. Hayes, H. C. Deeth, and A. L. Kelly. 2005. Significance of frictional heating for effects of high pressure homogenization on milk. *J. Dairy Res.* 72:393–399.
- Deru, M. and P. Torcellini. 2007. Source energy and emission factors for energy use in buildings. Technical report NREL/TP-550-38617, Revised June 2007. National Renewable Energy Laboratory (NREL), Golden, CO.
- Doty, S., and W. C. Turner. 2009. *Energy Management Handbook*. 7th ed. The Fairmount Press, Lilburn, GA.
- Eide, M. H., J. P. Homleid, and B. Mattsson. 2003. Life cycle assessment (LCA) of cleaning-in-place processes in dairies. *Lebenswiss. Technol.* 36:303–314.
- EPA (Environmental Protection Agency). 2012. Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1990–2010. EPA 430-R-12-001. United States Environmental Protection Agency, Washington, DC. Accessed Sep. 11, 2012. <http://www.epa.gov/climatechange/Downloads/ghgemissions/US-GHG-Inventory-2012-Main-Text.pdf>.
- Erba, E. M., R. D. Aplin, and M. W. Stephenson. 1997. An analysis of processing and distribution productivity and costs in 35 fluid milk plants. Cornell Program on Dairy Markets and Policy. Research Bulletin 97-03. Accessed Aug. 8, 2012. <http://dairy.wisc.edu/pubPod/pubs/RB9703.pdf>.
- FAO (Food and Agriculture Organization of the United Nations). 2010. Greenhouse gas emissions from the dairy sector: A life cycle assessment. FAO, Rome, Italy.
- FDA (Food and Drug Administration). 2011. US Department of Health and Human Services. Public Health Service. Grade “A”, Pasteurized Milk Ordinance. 2011 Revision. Accessed Nov. 12, 2012. <http://www.fda.gov/downloads/Food/FoodSafety/Product-SpecificInformation/MilkSafety/NationalConferenceonInterstateMilkShipmentsNCIMSDModelDocuments/UCM291757.pdf>.
- Graßhoff, A. 2002. Enzymatic cleaning of milk pasteurizers. *Food Bioprod. Process.* 80:247–252.
- Hoffman, W., C. Kiesner, I. Clawin-Rädecker, D. Martin, K. Einhoff, P. C. Lorenzen, H. Meisel, P. Hammer, G. Suhren, and P. Teufel. 2006. Processing of extended shelf-life milk using microfiltration. *Int. J. Dairy Technol.* 59:229–235.
- IDFA (International Dairy Foods Association). 2007. *DAIRY Facts Book*, 2007 Edition. IDFA, Washington, DC.
- IPCC (Intergovernmental Panel on Climate Change). 2007. *Climate Change 2007: Synthesis Report*. Contribution of working Groups I, II and III to the Fourth Assessment Report of the Intergovernmental Panel on Climate Change. Core Writing Team, R. K. Pachauri, and A. Reisinger, ed. IPCC, Geneva, Switzerland. Accessed Sep. 18, 2012. http://ipcc.ch/pdf/assessment-report/ar4/syr/ar4_syr.pdf.
- Jacobs, S. L., and G. K. Criner. 1990. *Milk Processing and Distribution Costs: The Maine Model*. Maine Agricultural Experiment Station, Technical Bulletin 140, May 1990. Department of Agricultural and Resource Economics, University of Maine, Orono.
- Juriaanse, A. J. 1999. Examples from dairy science show how descriptive science can be transferred into prescriptive knowledge. *Trends Food Sci. Technol.* 10:303–306.
- Kulozik, U. 2007. Procedures for the manufacture of milk with an extended shelf-life. Current techniques and new options. *Deutsche Milchwirtschaft* 58:268–271.
- Nicol, R. S., N. Kydas, and L. J. Robertson. 2005. World standard energy practice. Pages 3–10 in *Energy Use in Dairy Processing*. Bulletin of the International Dairy Federation. 401/2005. International Dairy Federation, Brussels, Belgium.
- NRCAN (Natural Resources Canada). 2001. *Energy performance indicator report: Fluid milk plants*. NRCAN, Ottawa, ON, Canada.
- Persson, P. A. 1987. Chapter 12: Dairy Plant. Pages 87–91 in *Food Factories: Processes, Equipment, Costs*. A. Bartholomai, ed. VCH Verlagsgesellschaft mbH, Weinheim, Germany.
- Peters, M. S., K. D. Timmerhaus, and R. E. West. 2003. *Plant Design and Economics for Chemical Engineers*. 5th ed. McGraw-Hill Book Co., New York, NY.
- Petrides, D., R. Cruz, and J. Calandranis. 1998. Optimization of wastewater treatment facilities using process simulation. *Comput. Chem. Eng.* 22(Suppl. 1):S339–S346.
- Ray, M. S., and M. G. Sneesby. 1998. *Chemical Engineering Design Project: A Case Study Approach*. 2nd ed. Gordon and Breach Science Publishers, Amsterdam, the Netherlands.
- Santamarina, V. E. 1997. Modeling and optimization of a municipal treatment plant using EnviroPro Designer. *Environ. Prog.* 16:268–273.
- Tan, A. J., D. W. Nutter, and F. Milani. 2011. GHG emissions and energy use from a multi-product dairy processing plant. 2011 ECTC Proc. ASME Early Career Technical Conference, Fayetteville, AR. Accessed Mar. 6, 2013. <http://districts.asme.org/DistrictE/ECTCPapers/2011Papers/ECTCpaper-AR-AJTan.pdf>.
- Thoma, G., J. Popp, D. Nutter, D. Shonnard, R. Ulrich, M. Matlock, D. S. Kim, Z. Neiderman, N. Kemper, C. East, and F. Adom. 2012. Greenhouse gas emissions from milk production and con-

- sumption in the United States: A cradle-to-grave life cycle assessment circa 2008. *Int. Dairy J.* <http://dx.doi.org/10.1016/j.idairyj.2012.08.013>.
- Toepfl, S., A. Mathys, V. Heinz, and D. Knorr. 2006. Review: Potential of high hydrostatic pressure and pulsed electric fields for energy efficient and environmentally friendly food processing. *Food Rev. Int.* 22:405–423.
- Tomasula, P. M., S. Mukhopadhyay, N. Datta, A. C. S. Porto-Fett, J. E. Call, J. B. Luchansky, J. Renye, and M. Tunick. 2011. Pilot-scale crossflow-microfiltration and pasteurization to remove spores of *Bacillus anthracis* (Sterne) from milk. *J. Dairy Sci.* 94:4277–4291. <http://dx.doi.org/10.3168/jds.2010-3879>.
- Tomasula, P. M., and D. W. Nutter. 2011. Mitigation of greenhouse gas emissions in the production of fluid milk. *Adv. Food Nutr. Res.* 62:41–88.
- US DOE (United States Department of Energy). 2010. Industrial Assessment Centers. Accessed Sep. 16, 2012. <http://iac.rutgers.edu/>.
- Van Asselt, A. J., G. Van Houwelingen, and M. C. Te Giffel. 2002. Monitoring system for improving cleaning efficiency of cleaning-in-place processes in dairy environments. *Food Bioprod. Process.* 80:276–280.
- Xu, T., and J. Flapper. 2009. Energy use and implications for efficiency strategies in global fluid-milk processing industry. *Energy Policy* 37:5334–5341.